

AUSTRALIAN  
COMMUNICATIONS  
INDUSTRY FORUM



AUSTRALIAN STANDARD

AS/ACIF S008:2006

Requirements for customer cabling products



## **Australian Standard – Requirements for customer cabling products**

This Standard was issued in draft form for public comment as DR AS/ACIF S008:2005

First Publication AS/ACIF S008:2001

Second Edition AS/ACIF S008:2006

ISBN: 1 74000 351 9

### **Disclaimers**

1. Notwithstanding anything contained in this Standard:
  - (a) ACIF disclaims responsibility (including where ACIF or any of its officers, employees, agents or contractors has been negligent) for any direct or indirect loss, damage, claim, or liability any person may incur as a result of any:
    - (i) reliance on or compliance with this Standard;
    - (ii) inaccuracy or inappropriateness of this Standard; or
    - (iii) inconsistency of this Standard with any law; and
  - (b) ACIF disclaims responsibility (including where ACIF or any of its officers, employees, agents or contractors has been negligent) for ensuring compliance by any person with this Standard.
2. The above disclaimers will not apply to the extent they are inconsistent with any relevant legislation.

### **Copyright**

© Australian Communications Industry Forum Limited 2006

This document is copyright and must not be used except as permitted below or under the Copyright Act 1968. You may reproduce and publish this document in whole or in part for your or your organisation's own personal or internal compliance, educational or non-commercial purposes. You must not alter or amend this document in any way. You must not reproduce or publish this document for commercial gain without the prior written consent of ACIF. Organisations wishing to reproduce or publish this document for commercial gain (i.e. for distribution to subscribers to an information service) may apply to subscribe to the ACIF Publications Subscription Service by contacting the ACIF Business Manager at [acif@acif.org.au](mailto:acif@acif.org.au). If you publish any part of this document for any purpose, you must also publish this copyright notice as part of that publication.

## FOREWORD

### General

This Standard was prepared by the ACIF *CECRP/WC 18 Cabling Standards* Working Committee. It is one of a series of Telecommunication Standards developed under the Memorandum of Understanding between the Australian Communications Authority (ACA) and the Australian Communications Industry Forum (ACIF).

Note: On 1 July 2005 the ACA became the Australian Communications and Media Authority (ACMA) and the Memorandum of Understanding between the ACA and ACIF continues in effect as if the reference to the ACA were a reference to ACMA.

This Standard is the result of a consensus among representatives on the ACIF Working Committee to produce it as an Australian Standard.

This Standard is a revision of AS/ACIF S008:2001 *Requirements for authorised cabling products*.

The requirements in this Standard are intended to be consistent with the aims of s376 of the *Telecommunications Act 1997*. Specifically these aims are—

- (a) protecting the integrity of a telecommunications network or facility;
- (b) protecting the health and safety of persons;
- (c) ensuring access to emergency services; and
- (d) ensuring interoperability with a standard telephone service.

It should be noted that some customer equipment (CE) may require demonstration of compliance with requirements in other Standards.

Applicable electrical safety Standards and EMC Standards may apply under Commonwealth or State laws, or both.

### Intellectual property rights

Equipment, which is manufactured to comply with this Standard may require the use of technology which is protected by patent rights in Australia. Questions about the availability of such technology, under licence or otherwise, should be directed to the patent holder or Australian licensee (if known) or through inquiry at IP Australia which incorporates the Patent, Trade Marks and Designs Offices. Further information can be found at [www.ipaustralia.gov.au](http://www.ipaustralia.gov.au).

## Standards revision

Australian Standards developed by the Australian Communications Industry Forum (AS/ACIF Standards) are updated, according to the needs of the industry, by amendments or revision. Users of AS/ACIF Standards should make sure that they possess the latest amendments or editions. Representations concerning the need for a change to this AS/ACIF Standard should be addressed to:

The Project Manager  
Customer Equipment and Cable Reference Panel  
The Australian Communications Industry Forum  
PO Box 444  
Milsons Point NSW 1565

## Regulatory notice

This document will be submitted to ACMA, for making as a technical standard under s376 of the *Telecommunications Act 1997*. Until it is made by ACMA compliance with this Standard is voluntary.

The Standard as made by ACMA will commence on the day after it registered under the Legislative Instruments Act 2003 (LIA) and it will be a disallowable instrument within the meaning of s46A of the *Acts Interpretation Act 1901*.

Details on current compliance arrangements can be obtained from the ACMA website at [www.acma.gov.au](http://www.acma.gov.au) or by contacting the ACMA below at:

Australian Communications and Media Authority  
PO Box 13112  
Law Courts PO  
Melbourne VIC 8010  
Australia

Telephone: +61 3 9963 6800  
Facsimile: +61 3 9963 6899  
TTY: +61 3 9963 6948

## Introduction

This introduction for the AS/ACIF S008:2006 **Requirements for customer cabling products** Standard is not an authoritative section of this Standard and is only provided as guidance for the user of the Standard to outline its objectives, the factors that have been taken into account in its development and to list the principle differences between the new and the previous edition.

The reader is directed to the clauses of this Standard for the specific requirements and to the Australian Communications and Media Authority (ACMA) for the applicable telecommunications labelling and compliance arrangements.

Note: Further information on the telecommunications labelling and compliance arrangements can be found in *The Telecommunications Labelling (Customer Equipment and Customer Cabling) Notice* (the TLN). The TLN can be obtained from the Australian Communications and Media Authority (ACMA) website at [www.acma.gov.au](http://www.acma.gov.au).

The objective of this Standard is to provide the requirements for cabling products and related customer equipment for safety and interoperability in order to meet the regulatory arrangements in Australia.

The objective of this revision is to update the requirements for—

- (i) advances in telecommunications technology such as blown fibre tube systems
- (ii) advances in building management systems such as equipment requiring the connection of telecommunications and electrical power cables; and
- (iii) products intended to make a connection through to a carrier's network such as those used in the computer industry, fire detection and alarm industry, and the security industry that may have been previously exempt.

The principle differences between this edition of AS/ACIF S008 and the previous edition are:

- (i) new definitions for 'special application cable', 'multi-discipline cable' and 'hybrid cable'
- (ii) new definition for 'MDF', replacing the term 'Network Boundary Distributor'
- (iii) voltage classifications have been grouped together in the definitions for clarity (e.g. if a circuit runs at say 100 V a.c. like some PA or EWIS systems, it is an LV circuit and therefore subject to all the separation rules in AS/ACIF S009)
- (iv) conductors and terminations of a customer cable may now be located adjacent to LV power cable and terminations under strict new rules for shared enclosures (Clause 5.4.1.3) overcoming regulatory difficulties for some devices such as those used in building management systems
- (v) cable requirements (Clause 5.6) have been reorganised into a set of requirements and a set of situations where those requirements must be applied.

- (vi) PVC insulation and sheath material elongation requirements in Tables 1 and 2 have been reduced to comply with current Australian and International Standards
- (vii) cable withstand voltages in Table 4 have been brought into line with current International Standards
- (viii) cables intended to be installed underground either in conduit or directly buried must pass the water penetration test (Clause 5.6.8) in line with Amendment 1 of the previous edition (now fully incorporated)
- (ix) new requirements for cables intended for aerial use containing integral bearer/strengthener (Clause 5.6.9)
- (x) claims about cable with special attributes such as rodent or termite protection are required to be supported by documentary evidence (Clause 5.6.10)
- (xi) cords with metallic conductors less than 10 m primarily intended for telephone or other non-data applications have been exempted from the insulation and sheath material requirements
- (xii) blown fibre tube systems are exempt from the water penetration test (Clause 5.6.17)
- (xiii) 600 series telephone sockets are no longer supported for new installations (the 8-position modular sockets are the higher performing replacement)
- (xiv) all references to a Network Termination Device Enclosure (NTDE) have been removed in line with the removal of the NTDE from AS/ACIF S009

---

## TABLE OF CONTENTS

---

<b>1</b>	<b>INTERPRETATION</b>	<b>1</b>
1.1	Categories of requirements	1
1.2	Compliance statements	1
1.3	Definitions, expressions and terms	1
1.4	Notes	1
1.5	References	1
1.6	Units and symbols	1
<b>2</b>	<b>SCOPE</b>	<b>2</b>
<b>3</b>	<b>REFERENCES</b>	<b>3</b>
<b>4</b>	<b>ABBREVIATIONS AND DEFINITIONS</b>	<b>5</b>
4.1	Abbreviations	5
4.2	Definitions	6
4.2.1	AC mains supply	6
4.2.2	Aerial cable	6
4.2.3	Cable	6
4.2.4	Cabling products	6
4.2.5	Carriage Service	6
4.2.6	Carriage service provider	6
4.2.7	Carrier	6
4.2.8	Certified Components List (CCL)	7
4.2.9	Communications Earth System (CES)	7
4.2.10	Compliant	7
4.2.11	Conduit	7
4.2.12	Connecting Hardware	7
4.2.13	Cord	7
4.2.14	Cordage	7
4.2.15	Customer Access Equipment (CAE)	7
4.2.16	Customer cabling	8
4.2.17	Customer Equipment (CE)	8
4.2.18	Distributor	8
4.2.19	Duct	8
4.2.20	Enclosure	8
4.2.21	Extra Low Voltage (ELV)	9
4.2.22	Facility	9
4.2.23	Hazardous voltage	9
4.2.24	High Voltage (HV)	9
4.2.25	Hybrid cable	9
4.2.26	Indoor cabling	9

4.2.27	<i>Jumper</i>	9
4.2.28	<i>Lead-in cabling</i>	9
4.2.29	<i>Line</i>	10
4.2.30	<i>Low Voltage (LV)</i>	10
4.2.31	<i>Multidiscipline cable</i>	10
4.2.32	<i>Main Distribution Frame (MDF)</i>	10
4.2.33	<i>Network Termination Device (NTD)</i>	10
4.2.34	<i>Outdoor cable</i>	10
4.2.35	<i>Pigtail</i>	10
4.2.36	<i>Power feeding</i>	11
4.2.37	<i>special application cable</i>	11
4.2.38	<i>Telecommunications network</i>	11
4.2.39	<i>Telecommunications Network Voltage (TNV) circuit</i>	11
4.2.40	<i>Trunking</i>	11
4.2.41	<i>Telephone cable</i>	11
4.2.42	<i>Underground cable</i>	11
4.2.43	<i>Voltage classifications</i>	12
<b>5</b>	<b>REQUIREMENTS</b>	<b>13</b>
<b>5.1</b>	<b>General</b>	<b>13</b>
<b>5.2</b>	<b>Markings</b>	<b>13</b>
5.2.1	<i>Labelling Notice</i>	13
5.2.2	<i>Inappropriate markings</i>	13
5.2.3	<i>Additional markings (excluding cable markings)</i>	13
<b>5.3</b>	<b>Underground conduit</b>	<b>13</b>
5.3.1	<i>Colour</i>	13
5.3.2	<i>Underground conduit properties</i>	14
5.3.3	<i>Underground conduit markings</i>	14
<b>5.4</b>	<b>Cable distribution devices</b>	<b>14</b>
5.4.1	<i>Common requirements</i>	14
5.4.2	<i>Main distribution frame (MDF)</i>	18
<b>5.5</b>	<b>5.5.1 Optical fibre distribution devices and enclosures</b>	<b>18</b>
<b>5.6</b>	<b>Cables</b>	<b>19</b>
5.6.1	<i>General</i>	19
5.6.2	<i>Conductor and optical fibre identification</i>	19
5.6.3	<i>Insulation and sheath material</i>	19
5.6.4	<i>Flammability</i>	19
5.6.5	<i>UV resistance</i>	19
5.6.6	<i>Metallic conductors</i>	20
5.6.7	<i>Metallic shield</i>	24
5.6.8	<i>Water penetration test</i>	24



---

5.6.9	<i>Integral bearer or strengthener</i>	24
5.6.10	<i>Cable with specific attributes</i>	25
5.6.11	<i>Metallic paired cable</i>	25
5.6.12	<i>Cordage with metallic conductors</i>	26
5.6.13	<i>Cords with metallic conductors</i>	26
5.6.14	<i>Metallic jumper wire and jumper cable</i>	27
5.6.15	<i>Coaxial cable</i>	27
5.6.16	<i>Optical fibre cable</i>	28
5.6.17	<i>Blown fibre tube systems</i>	29
5.6.18	<i>Special application cables</i>	29
<b>5.7</b>	<b>Connecting hardware, including plugs and sockets of all designs</b>	<b>32</b>
5.7.1	<i>General</i>	32
5.7.2	<i>Eight (8) position modular plugs and sockets</i>	33
5.7.3	<i>Six (6) position modular plugs and sockets</i>	33
5.7.4	<i>600 series plugs and sockets</i>	33
<b>5.8</b>	<b>Cabling products for underground and aerial installations</b>	<b>33</b>
5.8.1	<i>Pits</i>	33
5.8.2	<i>Underground joint/termination enclosures</i>	34
5.8.3	<i>Underground and aerial cable terminations</i>	34
5.8.4	<i>Pillars and cabinets</i>	34
5.8.5	<i>Aerial joint/termination enclosures</i>	35
<b>6</b>	<b>PARTICIPANTS</b>	<b>43</b>

---

---

## APPENDICES

---

<b>A</b>	<b>600 SERIES PLUGS AND SOCKETS</b>	<b>36</b>
<b>B</b>	<b>CABLE COLOUR CODES</b>	<b>38</b>

---

## FIGURES

---

<b>A1</b>	<b>MATING DIMENSIONS FOR 600 SERIES PLUGS AND SOCKETS</b>	<b>37</b>
-----------	---	-----------

---

## **TABLES**

---

<b>1</b>	<b>PVC INSULATION REQUIREMENTS</b>	<b>20</b>
<b>2</b>	<b>PVC SHEATH REQUIREMENTS</b>	<b>20</b>
<b>3</b>	<b>CONDUCTOR RESISTANCE</b>	<b>21</b>
<b>4</b>	<b>CABLE WITHSTAND VOLTAGES</b>	<b>21</b>
<b>5</b>	<b>METALLIC CABLE PERFORMANCE PARAMETERS</b>	<b>23</b>
<b>6</b>	<b>AUSTRALIAN STANDARDS APPLICABLE FOR CABLES USED IN SPECIAL APPLICATIONS</b>	<b>31</b>
<b>B1</b>	<b>2-PAIR (QUAD) AND 3-PAIR TELEPHONE CABLE COLOUR CODE</b>	<b>38</b>
<b>B2</b>	<b>1-PAIR TO 5-PAIR CABLE COLOUR CODE</b>	<b>38</b>
<b>B3</b>	<b>COLOUR CODE FOR 5-PAIR TO 100-PAIR CABLES (20-PAIR UNITS)</b>	<b>39</b>
<b>B4</b>	<b>COLOUR CODE FOR 25-PAIR TO 100-PAIR CABLES (25-PAIR UNITS)</b>	<b>40</b>
<b>B5</b>	<b>COLOUR CODE FOR 5-PAIR TO 100-PAIR CABLES (10-PAIR UNITS)</b>	<b>41</b>
<b>B6</b>	<b>COLOUR CODE FOR 5-PAIR TO 200-PAIR CABLES (10-PAIR UNITS)</b>	<b>41</b>
<b>B7</b>	<b>OPTICAL FIBRE COLOUR CODE</b>	<b>42</b>

# 1 INTERPRETATION

## 1.1 Categories of requirements

This Standard contains mandatory requirements as well as provisions that are recommendations only. Mandatory requirements are designated by the words '**shall**' or '**shall not**'. All other provisions are voluntary.

## 1.2 Compliance statements

Compliance statements, in italics, suggest methodologies for demonstrating Customer Cabling and related Customer Equipment compliance with the requirements.

## 1.3 Definitions, expressions and terms

If there is any conflict between the definitions used in this Standard and the definitions used in the *Telecommunications Act 1997*, the definitions in the *Act* take precedence.

## 1.4 Notes

Text denoted as 'Note' is for guidance in interpretation and is shown in smaller size type.

## 1.5 References

- (a) Applicable editions (or versions) of other documents referred to in this Standard are specified in Section 3: REFERENCES.
- (b) If a document refers to another document, the other document is a sub-referenced document.
- (c) Where the edition (or version) of the sub-referenced document is uniquely identified in the reference document, then that edition (or version) applies.
- (d) Where the edition (or version) of the sub-referenced document is not uniquely identified in the reference document, then the applicable edition (or version) is that which is current at the date the reference document is legislated under the applicable regulatory framework, or for a non- legislated document, the date upon which the document is published by the relevant standards organisation.
- (e) A number in square brackets '[' ]' refers to a document listed in Section 3: REFERENCES.

## 1.6 Units and symbols

In this Standard the International System (SI) of units and symbols is used in accordance with Australian Standard AS ISO 1000 [1].

## 2 SCOPE

This Standard applies to cabling products (including cable and related customer equipment) intended for connection to the customer side of the boundary of a telecommunications network.

This Standard does not apply to cabling products intended primarily for the distribution of AC mains supply.

This Standard does not apply to products intended to be used for telecommunications earthing systems or telecommunications power distribution (e.g. earthing/power conductors, earthing bars, busbars, earthing/power terminals, line tap devices, earth electrodes and associated fittings, batteries, fuses and circuit breakers).

A cabling product is not excluded from the scope of this Standard by reason only that it forms part of equipment that is subject to another Standard, for example, distribution frames or cable tails that form part of Customer Access Equipment (CAE).

Note 1: The connection of cabling products includes connection otherwise than by means of physical contact, e.g. a connection by means of radiocommunication.

Note 2: This Standard should be read in conjunction with AS/ACIF S009 which specifies the requirements for the installation and maintenance of fixed or concealed cabling or equipment that is connected or is intended to be connected to a telecommunications network.

### 3 REFERENCES

	<b>Publication</b>	<b>Title</b>
	<b>Australian Standards</b>	
[1]	AS ISO 1000:1998	The international System of Units (SI) and its application
[2]	AS 1049:2003	Telecommunication cables—Insulation, sheath and jacket
[3]	AS/NZS 1574:1996	Copper and copper alloys —Wires for electrical purposes
	AS/NZS 1660	Test methods for electric cables, cords and conductors
[4]	AS/NZS 1660.3:1998	Part 3: Electrical tests (including Amdt 1: 2001)
	AS/NZS 1660	Test methods for electric cables, cords and conductors
[5]	AS/NZS 1660.5.6:2005	Part 5.6: Fire Tests – Test for vertical flame propagation for a single insulated wire or cable
[6]	AS/NZS 1802:2003	Electric cables – Reeling and trailing – For underground coal mining purposes
	AS/NZS 2053	Conduits and fittings for electrical installations
[7]	AS/NZS 2053.1:2001	Part 1: General requirements
	AS/NZS 2211	Safety of laser products
[8]	AS/NZS 2211.1:2004	Part 1: Equipment classification requirements and user's guide (IEC 60852-1: 2001 MOD)
[9]	AS/NZS 2373:2003	Electric cables – twisted pair for control and protection circuits
[10]	AS/NZS 3000:2000	Electrical installations (known as the Australian/New Zealand Wiring Rules)
[11]	AS/NZS 3188:1995	Approval and test specification- Terminations and glands for mineral insulated metal-sheathed cables
[12]	AS/NZS 3191:2003	Electric flexible cords
	AS 3726	Electromechanical components for electronic equipment—Basic testing procedures and measuring methods
[13]	AS 3726.2:1989	Part 2: General examination, electrical continuity and contact resistance tests, insulation tests and voltage stress tests. (Only test 3a is referenced)
[14]	AS/NZS 4117:1999	Surge Protection Devices for Telecommunication Applications
[15]	AS/NZS 5000.1:2003	Electric cables – polymeric insulated. For working voltages up to and including 0.6/1 (1.2) kV

	AS/NZS 5000	Electric cables
[16]	AS/NZS 5000.2:1999	Part 2: Polymeric insulated. For working voltages up to and including 450/750 V
	AS/NZS 5000	Electrical cables – polymeric insulated
[17]	AS/NZS 5000.3:2003	Part 3: Multicore control cables
[18]	AS 60529:2004	Degrees of protection provided by enclosures (IP Code)
[19]	AS/NZS 60695.2.13:2001	Fire hazard testing – glowing/hot wire based test methods – glow-wire ignitability test method for materials
	AS/NZS 60950	Information Technology Equipment - Safety
[20]	AS/NZS 60950.1:2003	Part 1: General requirements
	<b>AS/ACIF Standards</b>	
[21]	AS/ACIF S009:2006	Installation requirements for customer cabling – Wiring Rules
	<b>IEC Publications</b>	
[22]	IEC 60096-1:1986	Radio-frequency cables. Part 1: General requirements and measuring methods
[23]	IEC 60189-1:1986	Low-frequency cables and wires with PVC insulation and PVC sheath. Part 1: General test and measuring methods
[24]	IEC 60352-4:1994	Solderless non-accessible insulation displacement connections – General requirements, test methods and practical guidance
[25]	IEC 60603-7:1996	Connectors for frequencies below 3 MHz for use with printed boards Part 7: Detail specification for connectors, 8-way, including fixed and free connectors with common mating features, with assessed quality
[26]	IEC 60793-2:2003	Optical fibres. Part 2: Product specification - General
[27]	IEC 60794-1-1:2001	Optical fibre cables - Part 1-1 – General
[28]	IEC 60794-1-2:2003	Optical fibre cables - Part 1-2 – Basic optical cable test procedures. (for Water Penetration Test)
	<b>Other References</b>	
[29]	CFR FCC 47— Part 68.500: October 2000	Code of Federal Regulations Federal Communications Commission Title 47: Telecommunications Part 68: Connection of terminal equipment to the telephone network Sub part F: Connector Specifications. Paragraph 500: Specifications

## 4 ABBREVIATIONS AND DEFINITIONS

For the purposes of this Standard, the following abbreviations and definitions apply.

### 4.1 Abbreviations

AC (or a.c.)	alternating current (in r.m.s. value unless stated otherwise)
ACIF	Australian Communications Industry Forum
ACMA	Australian Communications and Media Authority
AS	Australian Standard
CAE	Customer Access Equipment
CE	Customer Equipment
CES	Communications Earth System
DC (or d.c.)	direct current
ELV	Extra-Low Voltage
FCC	Federal Communications Commission USA
HV	High Voltage
IEC	International Electrotechnical Commission
IP	International Protection (rating) (sometimes referred to as Ingress Protection)
IPXn	rated for protection against ingress of water only (n = 0 to 8, according to the degree of protection specified)
ISDN	Integrated Services Digital Network
LAN	Local Area Network
LV	Low Voltage
MDF	Main Distribution Frame
MIMS	Mineral Insulated Metal Sheath
NTD	Network Termination Device
NZS	New Zealand Standard
PVC	Polyvinyl Chloride
SWA	Steel Wire Armouring
TNV	Telecommunications Network Voltage
TO	Telecommunications Outlet
TRC	Telecommunications Reference Conductor
TS	Technical Standard
UV	UltraViolet (radiation/light)
Z <sub>0</sub>	Characteristic Impedance

## **4.2 Definitions**

### **4.2.1 AC mains supply**

An AC power distribution system external to the equipment for supplying power to AC powered equipment

Note 1: Power sources may include public or private utilities and equivalent sources such as motor-driven generators and uninterruptible power supplies.

Note 2: Adapted from AS/NZS 60950.1 [20].

### **4.2.2 Aerial cable**

Cable that is suspended between poles, buildings or other supporting structures external to a building.

### **4.2.3 Cable**

An assembly of one or more cable units (e.g. pairs, quads, coaxial tubes, fibres) in an overall sheath.

Note: The assembly may include such things as a shield, moisture barrier, filling compound, strengthener or bearer wire.

### **4.2.4 Cabling product**

A passive device (including any cable, connecting hardware or surge suppression device) that is intended for use on the customer side of the boundary of a telecommunications network.

### **4.2.5 Carriage Service**

A service for carrying communications by means of guided and/or unguided electromagnetic energy.

### **4.2.6 Carriage service provider**

If a person supplies, or proposes to supply, a listed carriage service to the public using:

- (a) a network unit owned by one or more carriers; or
- (b) a network unit in relation to which a nominated carrier declaration is in force;

the person is a carriage service provider.

### **4.2.7 Carrier**

The holder of a carrier licence.



#### 4.2.8 Certified Components List (CCL)

The list that was established by AUSTEL and is published by ACMA on its website.

Note 1: AUSTEL and the Spectrum Management Agency merged in the creation of the Australian Communications Authority (ACA) on 1 July 1997. The ACA and the Australian Broadcasting Authority (ABA) merged in the creation of the Australian Communications and Media Authority (ACMA) on 1 July 2005.

Note 2: The use of the CCL was discontinued on 1 July 1997, but remains in force in accordance with ACA TS 102–1998 *Telecommunications Technical Standard (Customer Equipment and Customer Cabling)*.

#### 4.2.9 Communications Earth System (CES)

A system of earthing using common elements to provide for earthing of electrical and communications equipment within a premises.

Note: A CES may be used for protective and functional earthing for telecommunications purposes.

#### 4.2.10 Compliant

An item that has been labelled in accordance with the Telecommunications Labelling Notice.

#### 4.2.11 Conduit

A tube or pipe that physically accommodates cables.

Note: In this Standard, conduit and pipe have the same meaning. See also 'Duct' and 'Trunking'

#### 4.2.12 Connecting Hardware

A passive device used to join or interconnect lines, or to connect customer equipment to a line.

#### 4.2.13 Cord

A flexible cable with a minimum of one termination (e.g. on a plug).

Note: Cords are used for connection of moveable customer equipment or to afford flexibility, e.g. includes patch cords, fly leads and pigtails.

#### 4.2.14 Cordage

A flexible cable that is not fitted with connectors, which may be used in the assembly of cords.

#### 4.2.15 Customer Access Equipment (CAE)

Customer equipment with multiple ports (local or network) that provides access (gateway functions) to a telecommunications network and is capable of switching, storage, processing,

conversion, integration, line isolation/coupling or multiplexing of analogue or digital voice or voice equivalent communication

Note 1: Examples of CAE include, but are not limited to, PABX or key systems, line isolators, ISDN terminal adapters, echo cancellers, interactive voice response systems, voice/packet gateway, integrated access devices and voice messaging systems.

Note 2: CAE was formerly referred to as CSS (customer switching system).

#### 4.2.16 Customer cabling

A line that is used, installed ready for use or intended for use on the customer side of the boundary of a telecommunications network.

Note: In the context of this Standard a reference to customer cabling is a reference to cable including cord and cordage.

#### 4.2.17 Customer Equipment (CE)

(a) any equipment, apparatus, tower, mast, antenna or other structure or thing; or

(b) any system (whether software-based or otherwise);

that:

(1) is used, installed ready for use or intended for use in connection with a carriage service; and

(2) under the regulations, is treated as customer equipment;

but does not include a line.

Note: In the context of this Standard a reference to customer equipment is a reference to all products excluding cable, cord and cordage.

#### 4.2.18 Distributor

A collection of components used to terminate cables and which provide for cross-connection of lines.

Note 1: An example of a distributor is a jumperable distribution frame or a patch panel.

Note 2: Where cable termination equipment is used to interconnect two or more cables without cross-connection, for the purposes of this Standard, it is not regarded as a distributor.

#### 4.2.19 Duct

A closed passage for housing and protecting cables and conductors. See also 'Conduit' and 'Trunking'.

#### 4.2.20 Enclosure

A housing or covering for cables or equipment providing an appropriate degree of protection against external influences or end-user contact with hazardous voltages, ELV or TNV.

- 4.2.21 Extra Low Voltage (ELV)  
See 'Voltage classifications'.
- 4.2.22 Facility
- (a) any part of the infrastructure of a telecommunications network; or
  - (b) any line, equipment, apparatus, tower, mast, antenna, tunnel, duct, hole, pit, pole or other structure or thing used, or for use, in or in connection with a telecommunications network.
- 4.2.23 Hazardous voltage  
See 'Voltage classifications'.
- 4.2.24 High Voltage (HV)  
See 'Voltage classifications'.
- 4.2.25 Hybrid cable  
A composite cable that—
- (a) uses separate telecommunications technologies; or
  - (b) is used simultaneously for telecommunications and an application other than telecommunications.
- Note 1: The telecommunications component of a hybrid cable is required to meet the applicable requirements of this Standard.
- Note 2: An example of a hybrid cable is a cable composed of a coaxial tube and twisted pairs contained under the same sheath.
- Note 3: Another example of a hybrid cable is a cable that is used for distribution or connection of ELV power and that also contains an optical fibre, coaxial tube or metallic conductors for control purposes.
- 4.2.26 Indoor cabling  
Customer cabling that is intended for use inside a building, but not underground or exposed to the elements.
- 4.2.27 Jumper  
A cable unit or cable element without connectors, typically one to four twisted pairs, either unsheathed or sheathed, used to make a cross connection within a distributor.
- 4.2.28 Lead-in cabling  
A carrier's telecommunications network cabling from the carrier's distribution point to the boundary of a telecommunications network.

4.2.29 Line

A wire, cable, optical fibre, tube, conduit, waveguide or other physical medium used, or for use, as a continuous artificial guide for or in connection with carrying communications by means of guided electromagnetic energy.

4.2.30 Low Voltage (LV)

See 'Voltage classifications'.

4.2.31 Multidiscipline cable

A cable that is intended to be used for an application other than telecommunications but excluding any cable normally used for distribution or connection of AC mains supply.

Note: An example of a multidiscipline cable is a cable that may be used for telecommunications or may be used for such other things as—

- (a) emergency lighting (e.g. MIMS cable);
- (b) distribution or connection of ELV power (e.g. 'figure 8' twin conductor cable); or
- (c) control purposes (e.g. a travelling lift or hoist cable).

4.2.32 Main Distribution Frame (MDF)

A distributor that provides, or is intended to provide, an electrical termination point for a carrier's lead-in cabling.

Note: There may be more than one MDF within a building.

4.2.33 Network Termination Device (NTD)

A device meeting the carrier's requirements and which is provided by the carrier to establish a demarcation point between the carrier's telecommunications network and customer cabling or customer equipment. An NTD is permanently marked at manufacture with the words 'Network Termination Device' or the letters 'NTD'.

Note: Any device that is not identified as described above is not a network termination device.

4.2.34 Outdoor cable

Cable that is intended for use external to a building and is either underground or exposed to the elements, including aerial cable.

4.2.35 Pigtail

A length of metallic or optical fibre cordage with a connector fitted at one end only. The other end is free for terminating or splicing to customer equipment or customer cabling.

4.2.36 Power feeding

The transfer of electrical power (usually DC) over a telecommunications line for telecommunications purposes to operate a powered device.

4.2.37 Special application cable

A cable that—

- (a) is intended to carry steady-state or change-of-state DC signals or AC signals less than 300 Hz between devices;
- (b) is a cable intended to carry an industrial data signalling protocol, e.g. RS232 or RS485;
- (c) is intended for multidiscipline use; or
- (d) is a hybrid cable.

Note: A special application cable may include, but is not limited to—

- (a) a cable used for connection of telecommunications power (usually SELV) and associated status and alarm circuits;
- (b) a MIMS, EWIS or other fire detection or fire warning system cable;
- (c) a security or control system cable; or
- (d) a travelling lift or hoist cable.

4.2.38 Telecommunications network

A system, or series of systems that is operated by a carrier or carriage service provider and which carries, or is capable of carrying, communications by means of guided and/or unguided electromagnetic energy.

4.2.39 Telecommunications Network Voltage (TNV) circuit

See 'Voltage classifications'

4.2.40 Telephone cable

A cable with metallic conductors (including cordage or a cord) designed to carry signals only in the 300 Hz to 100 kHz bandwidth.

4.2.41 Trunking

A tray or trough system with removable cover(s) along its length for housing and protecting cables.

Note: See also 'Conduit' and 'Duct'.

4.2.42 Underground cable

Cable that is intended to be buried underground either directly or in conduit.

4.2.43 Voltage classifications

4.2.43.1 Extra-low voltage (ELV)

ELV is a voltage not exceeding 42.4 V peak or 60 V d.c.

Note: This differs from the ELV definition contained in AS/NZS 3000 [10], which is more closely aligned to the TNV limits described below, i.e. 120 V d.c. or 70.7 V a.c. peak (50 V a.c. r.m.s.).

4.2.43.2 Telecommunications network voltage (TNV)

TNV is a voltage not exceeding—

(a) when telephone ringing signals are not present—

(i) 71 V peak or 120 V d.c.; or

(ii) if a combination of AC voltage and DC voltage is present, the sum of the AC peak voltage divided by 71 and the DC voltage divided by 120 must not exceed 1; and

(b) when telephone ringing signals are present, voltages such that the signal complies with the criteria of either Clause M.2 or Clause M.3 of AS/NZS 60950.1 [20] (the signal is required to be current limited and cadenced).

Note: Adapted from AS/NZS 60950.1.

4.2.43.3 Low voltage (LV)

LV is a voltage exceeding ELV limits but not exceeding 1000 V a.c. or 1500 V d.c.

4.2.43.4 High voltage (HV)

HV is a voltage exceeding LV limits.

4.2.43.5 Hazardous voltage

A hazardous voltage is a voltage exceeding ELV limits existing in a circuit which does not meet the requirements for either a limited current circuit or a TNV circuit as defined in AS/ACIF S009 [21].

## 5 REQUIREMENTS

### 5.1 General

Cabling products **shall** be physically distinguishable from products used for distribution or connection of AC mains supply.

### 5.2 Markings

#### 5.2.1 Labelling Notice

The Telecommunications Labelling Notice (TLN) requirements apply to customer cable or related CE.

Note 1: The TLN does not apply to cable and cabling products that are not used for customer cabling or related CE (see category A22 in Part 2 of Schedule 1 of the TLN).

Note 2: The TLN is available from the ACMA website at [www.acma.gov.au](http://www.acma.gov.au).

#### 5.2.2 Inappropriate markings

Cabling products intended solely for telecommunications use **shall not** bear markings indicating hazardous services.

#### 5.2.3 Additional markings (excluding cable markings)

##### 5.2.3.1 International Protection (IP) rating

Cabling products other than cable, which have been assessed against the requirements of AS 60529 [18] **shall** be legibly and durably marked with the relevant International Protection (IP) rating.

Note: It is recommended that the IP rating along with other markings required by this Standard are located in a visible external or internal position after installation.

##### 5.2.3.2 Multidiscipline telecommunications connecting hardware

Products designed for multidiscipline use that have permanent markings to distinguish their usage **shall** have their markings positioned so that they are likely to be visible when the products are installed.

Note: This is to distinguish the cabling products used for telecommunications from those products used for hazardous circuits.

### 5.3 Underground conduit

#### 5.3.1 Colour

Non-metallic conduit for underground use **shall be—**

(a) coloured white; or

- (b) contain an indelible, durable, continuous white stripe which is incorporated as part of the manufacturing process and is not painted on or applied over the surface of a pre-fabricated conduit.

### 5.3.2 Underground conduit properties

Underground conduit **shall** meet the following minimum classifications in accordance with Clause 5 of AS/NZS 2053.1 [7]:

- 5.1 Any of the listed types of material;
- 5.2 Threadable or non-threadable;
- 5.3 Medium mechanical stresses ('medium duty');
- 5.4 Rigid or flexible;
- 5.8.1 & 5.8.2 Rated to IP66; and
- 5.8.5 Non-hygroscopic.

### 5.3.3 Underground conduit markings

#### 5.3.3.1 General

Non-metallic conduit for underground use **shall** be legibly and durably marked 'COMMUNICATIONS' at intervals of no less than 1 m and no greater than 3 m.

Note 1: Conduit fittings such as bends and joiners do not need to be marked.

Note 2: Suitable methods of marking include stamping, moulding, printed labels and direct printing.

#### 5.3.3.2 Marking durability

The marking **shall**—

- (a) be durable and easily legible after rubbing the marking by hand; and
- (b) withstand being rubbed by hand for 15 s with a piece of cloth soaked with water and again for 15 s with a piece of cloth soaked with petroleum spirit.

Note: Petroleum spirit is defined as the aliphatic solvent hexane with a maximum aromatics content of 0.1% by volume, a Kauri-butanol value of 29, an initial boiling point of 65°C, a dry point of 69°C and a density of approximately 0.68 g/cm<sup>3</sup>.

## 5.4 Cable distribution devices

### 5.4.1 Common requirements

#### 5.4.1.1 Cable entry

Cable entry holes **shall** be free of sharp edges or burrs or have a grommet of insulating material fitted.



5.4.1.2 Conductive enclosure

5.4.1.2.1 Enclosure, frame and backmount earthing

Provision **shall** be made to enable conductive enclosures, frames and backmounts to be connected to the building electrical earthing system in accordance with the applicable requirements of AS/ACIF S009 [21].

5.4.1.2.2 Insulation

All parts intended to carry voltages up to TNV, except connecting hardware that is tested separately to Clause 5.7, **shall** be electrically insulated to a minimum value of 1.5 kV a.c. (50 Hz) without breakdown for 60 s from any conductive part of enclosures, or terminals provided to make a connection to the enclosure itself.

Note Face plates and mounting hardware intended for use with generic or proprietary connectors are required to comply with this Clause. Connecting hardware that is separately tested under Clause 5.7 is exempt from this Clause.

5.4.1.3 Enclosure requirements

5.4.1.3.1 Openings

Any openings, other than cable entries, in enclosures **shall** comply with the physical requirements for electrical enclosures given in Clause 4.6 of AS/NZS 60950.1 [20].

5.4.1.3.2 Sharp edges

An enclosure **shall** be free from exposed sharp edges that may cause damage to cable or injury to any person.

5.4.1.3.3 Outdoor enclosures

Enclosures intended for outdoor installation **shall** provide a minimum degree of protection of IPX3 in accordance with AS 60529 [18].

*Compliance with Clause 5.4.1.3.3 should be checked after the enclosure has been opened and closed at least ten (10) times.*

5.4.1.3.4 Shared enclosures

The conductors and terminations of a customer cable may be located within the same enclosure as the conductors and terminations of an LV power cable subject to the following:

- (a) The conductors and terminations of a customer cable **shall not** be located within the same enclosure as the uninsulated and single-insulated conductors and terminations of an LV power cable unless—
  - (i) accidental access to the LV power conductors and terminations by persons working on the customer cable conductors and terminations is prevented by means of a

physical barrier or obstruction that prevents contact with the LV power conductors or terminations by any part of the body or by any tool being used by the cabling provider; or

- (ii) the customer cable and the LV power cable are to be terminated on building control or monitoring equipment that is to be installed in a restricted access location where only persons who are qualified and authorised to install or maintain both LV power installations and customer cabling can gain access.

Note: 'Restricted access location' means a locked room or enclosure where appropriate signage is used to ensure accidental access is not obtained by persons who are not qualified or authorised to gain access.

- (b) The conductors and terminations of a customer cable **shall** be separated from the uninsulated and single-insulated conductors and terminations of an LV power cable by either a minimum distance of 150 mm or by means of a permanent, rigidly-fixed barrier of durable insulating material or metal that is capable of being earthed in accordance with Clause 5.4.1.3.4(c), unless—

- (i) the customer cable and the LV power cable are to be terminated on building control or monitoring equipment that is to be installed in a restricted access location where only persons who are qualified and authorised to install or maintain both LV power installations and customer cabling will be able to gain access;

- (ii) separate cables are to be used for LV power and telecommunications; and

- (iii) any telecommunications circuit that is to be terminated on the building control or monitoring equipment—

- (A) will not share the same cable sheath as any other telecommunications service; and

- (B) will only be connected to a telecommunications network via a compliant isolating interface.

Note 1: 'Restricted access location' means a locked room or enclosure where appropriate signage is used to ensure accidental access is not obtained by persons who are not qualified or authorised to gain access.

Note 2: 'Compliant isolating interface' means carrier equipment or customer equipment that meets the requirements of AS/NZS 60950.1 [20] for a TNV 1, TNV 2 or TNV 3 interface, as applicable to the circumstances. Examples are a modem or a line isolation unit (LIU).

- (c) Where the barrier referred to in Clause 5.4.1.3.4(b) is of metallic construction, provision **shall** be made for connecting the barrier to a protective earth by a minimum 2.5 mm<sup>2</sup> conductor.
- (d) Conductors and terminations of telecommunications cables **shall not** be located within the same enclosure as those of HV cables.

#### 5.4.1.4 Earthing or bonding bars and terminals

##### 5.4.1.4.1 Insulation

Earthing/bonding bars and terminals, where provided, **shall** be insulated from any conductive material of the enclosure, backmount or frame to withstand a potential difference of 1.5 kV a.c. (50 Hz) for 60 s.

##### 5.4.1.4.2 Earthing or bonding conductor connections

An earthing/bonding bar or terminal intended for connection of earthing or bonding conductors **shall** comply with the requirements of AS/ACIF S009 [21] for earthing/bonding bars and terminals used for connection of earthing or bonding conductors.

##### 5.4.1.5 Surge suppression devices

Where surge suppression is installed on twisted pair cable for any reason and—

- (a) is connected between telecommunications line conductors and earth; and
- (b) is installed in the customer cabling (e.g. at a distributor, terminal block or joint);

the device **shall** meet the requirements of AS/NZS 4117 [14] for—

- (1) either a Class 1 or a Class 3 device where installed within an MDF; or
- (2) a Class 1 device for any other location.

Note 1: Class 1 devices to AS/NZS 4117 [14] should have a specified minimum DC firing voltage of 400 V d.c. to the common (earth) terminal. A device with a nominal firing voltage of between 500 V d.c. and 600 V d.c. will normally be required to allow for manufacturing tolerances.

Note 2: Class 3 devices to AS/NZS 4117 [14] should have a specified minimum DC firing voltage of 190 V d.c. to the common (earth terminal). A device with a nominal firing voltage of 230 V d.c. will normally be required to allow for manufacturing tolerances.

Note 3: Both Class 1 and Class 3 devices should have a maximum limiting voltage of 1200 V d.c. and a holdover test voltage of at least 52 V d.c.

Note 4: The reason a Class 3 device is allowable in Item (1) is in recognition of the higher integrity of a hard-wired earth at an MDF.

Note 5: Surge suppression devices installed on any lines carrying voltages exceeding 50 V d.c. (e.g. for remote power feeding) should have a specified minimum DC firing voltage and holdover voltage exceeding the normal DC line voltage.

#### 5.4.2 Main distribution frame (MDF)

##### 5.4.2.1 Flame propagation

The MDF enclosure case materials **shall** be tested and meet the minimum requirements of—

- (a) a resistance to heat to 120°C in accordance with AS/NZS 2053.1 [7];
- (b) non-flame propagating in accordance with AS/NZS 2053.1 [7]; and
- (c) if made of insulating material, the glow wire test of AS/NZS 60695.2.13 [19] at 850°C.

Note This requirement is to allow for the installation of surge suppression fittings within the MDF, which may become a source of ignition during overvoltage conditions.

##### 5.4.2.2 Security

The MDF **shall** have provision for securing with a key, lock or tool.

##### 5.4.2.3 Terminations

The MDF should be suitable for mounting the carrier's standard terminating modules for lead-in cabling on the carrier's side of the distributor.

Note: Manufacturers should be aware that the carrier may deny access to their network if they are unable to mount their terminating modules for termination of their lead-in cabling in the MDF.

##### 5.4.2.4 Space for surge suppression devices

Allowance **shall** be made for a minimum clearance of 30 mm between the carrier's standard termination modules and the inside face of the front cover or door of the MDF in the fully closed position, to allow for the fitting of surge suppression devices.

Note: Appropriate clearance should be provided on the customer's side to fit surge suppression, test devices or other devices.

## 5.5 Optical fibre distribution devices and enclosures

Optical fibre distribution devices and splice enclosures **shall** comply with the applicable laser class and labelling requirements as specified in AS/NZS 2211.1 [8].

## 5.6 Cables

### 5.6.1 General

A customer cable **shall** meet the requirements of Clauses 5.6.2 to 5.6.9 where specified in Clauses 5.6.10 to 5.6.18 of this Standard, in addition to any other requirements specified for the particular type of cable or cable application.

### 5.6.2 Conductor and optical fibre identification

A cable that is required to comply with this Clause, and which contains more than one metallic conductor, coaxial tube or optical fibre, **shall** use a system of identification such that all conductors, coaxial tubes or optical fibres within the cable are readily distinguishable visually from one another.

Note: Examples of colour codes are set out in Appendix B.

### 5.6.3 Insulation and sheath material

A cable that is required to comply with this Clause—

- (a) **shall** use insulation and sheath materials suitable for telecommunications purposes;
- (b) where PVC insulation or sheath materials are used, they **shall** comply with the requirements of Table 1 or 2, as applicable; and
- (c) where non-PVC insulation or sheath materials are used, they **shall** comply with the requirements of AS 1049 [2] for—
  - (i) Tensile Strength Test (Aged/Unaged);
  - (ii) Elongation Test (Aged/Unaged); and
  - (iii) Shrinkback Tests for that particular type of insulation and sheath.

### 5.6.4 Flammability

A cable that is required to comply with this Clause **shall** pass the combustion propagation test of Method 5.6 including Appendix A and B of AS 1660.5.6 [5].

### 5.6.5 UV resistance

A cable that is required to comply with this Clause **shall** meet the requirements of AS 1049 [2] for cables exposed to UV radiation.

Note: Underground cable is likely be exposed to UV radiation (sunlight) at points where it enters or exits the ground or if a pit or access hole cover is dislodged or damaged for an extended period.

*Compliance is assessed by the manufacturer's declaration stating the basis of the declaration, which may include known properties of the material used.*

**Table 1**  
**PVC insulation requirements**

Property	Value	Conditions	Test method
Tensile Strength	18 MPa (minimum)	Unaged	AS1049 Appendix E
Elongation at Break	100% (minimum)	Unaged	AS1049 Appendix E
Elongation at break after aging	50% (minimum) of initial.	After aging, at 100 °C for 120 h	AS1049 Appendix E
Volatile loss	20 g/m <sup>2</sup> (maximum)	After aging, at 80 °C for 120 h	AS1049 Appendix R
Volume resistivity	400 GΩ m (minimum) 0.4 GΩ m (minimum)	at 23 °C at 60 °C	AS1049 Appendix AA

**Table 2**  
**PVC sheath requirements**

Property	Value	Conditions	Test method
Tensile Strength	12 MPa (minimum)	Unaged	AS1049 Appendix E
Elongation at Break	100% (minimum)	Unaged	AS1049 Appendix E
Elongation at break after aging	50% (minimum) of initial.	After aging at 100 °C for 120 h	AS1049 Appendix E
Volatile loss	20 g/m <sup>2</sup> (maximum)	After aging at 80 °C for 120 h	AS1049 Appendix R

#### 5.6.6 Metallic conductors

##### 5.6.6.1 Conductor composition

Where a cable is required to comply with this Clause, any metallic conductors, other than copper-clad steel used as an inner conductor in coaxial cable—

- (a) **shall** be either plain or plated copper;
- (b) may be either a single, solid conductor or multi-stranded;
- (c) the DC resistance **shall** be less than the values given in Table 3; and
- (d) the conductor finish should be plain or tinned.

##### 5.6.6.2 Electrical withstand voltage

A multi-conductor cable that is required to comply with this Clause, when tested at a frequency of 50 Hz on at least 1 m length;

- (a) **shall** be able to withstand the appropriate AC voltage levels and test method listed in Table 4, without breakdown for a period of 60 s or a period of 2 s as stated; and

- (b) for Test 2 and 3, all cables/cordages **shall** comply to the Table 4 limits using the test specified in AS/NZS 3191 [12] Table 2.1, test number 8(a), and using test method referred in Clause 3.5.1 of AS/NZS 1660.3 [4].

Note: Alternatively, the test may be performed using a DC potential equal to the peak voltage of the prescribed AC voltage.

**Table 3**  
**Conductor resistance**

Wire type	Resistance $\Omega/\text{km} @ 20^\circ\text{C}$
Single strand of plain annealed copper	$24/d^2$
Single strand of plated annealed copper	$26/d^2$
Bunched strands of plain or plated copper	$28/N.d^2$

where:  $N$  is the number of strands

$d$  is nominal diameter of individual strands or solid single strand in millimetres

Note 1: The DC resistance is based on the diameter of the strand, or in the case of multi stranded conductors, on the number of strands and the diameter of the individual strands.

Note 2: The recommended conductor diameter for copper conductors is in the range 0.4 mm to 0.9 mm.

**Table 4**  
**Cable withstand voltages**

Test number	High voltage test	Cordage (kV a.c.)	Indoor cable (kV a.c.)	Outdoor cable (kV a.c.)
1	Conductor to core Test voltage applied between each conductor and all remaining conductors and to shield if applicable.	0.7 (or 1.7 for 2 s)	1.5	2.0
2	Core to sheath Test voltage applied between all conductors bunched together and sheath exterior or SWA if applicable.	0.7 (or 1.7 for 2 s)	3.0	4.5
3	Shield to sheath (where applicable) Test voltage applied between shield and sheath exterior.	1.5	3.0	4.5

### 5.6.6.3 Mutual capacitance

Where a cable is required to comply with this Clause, the following requirements are to be met:

- (a) The maximum mutual capacitance between the two wires forming a pair measured at any frequency in the range 800 Hz to 1000 Hz **shall not** exceed the relevant value given in Table 5.
- (b) The measurement, referred to in Clause 5.6.6.3(a) **shall** be performed on a minimum cable length of 100 m, in accordance with Clause 5.4 of IEC 60189-1 [23] except as varied in Clause 5.6.6.3(c) below.
- (c) The mutual capacitance **shall** be corrected to a length of 1000 m by application of the following equation:

$$\text{Value corrected to 1000 m length} = \text{measured value} \times \frac{1000}{L}$$

where:  $L$  is the length in metres of the cable under test

### 5.6.6.4 Capacitance unbalance

Where a cable is required to comply with this Clause, the following requirements are to be met:

- (a) The maximum capacitance unbalance between pairs measured at any frequency in the range 800 Hz to 1000 Hz **shall not** exceed the relevant value given in Table 5.
- (b) During the measurement referred to in Clause 5.6.6.4(a), all conductors, other than those under test and the metallic shield (where applicable) **shall** be connected to earth.
- (c) The measurement **shall** be performed on a minimum cable length of 100 m, in accordance with Clause 5.5 of IEC 60189-1 [23] except as varied in Clause 5.6.6.4(e) below.
- (d) The capacitance unbalance between two pairs of wires with one pair designated 'A' and 'B' and the second pair designated 'C' and 'D' is given by the following expression:

$$(W + Y) - (X + Z)$$

where:  $W$  is the capacitance between the 'A' and 'C' wires

$Z$  is the capacitance between the 'A' and 'D' wires

$X$  is the capacitance between the 'B' and 'C' wires

$Y$  is the capacitance between the 'B' and 'D' wires

- (e) The capacitance unbalance **shall** be corrected to a length of 500 m by application of the following equation:



$$\text{Value corrected to 500 m length} = \frac{\text{measured value}}{\sqrt{L/500}}$$

where:  $L$  is the length in metres of the cable under test

#### 5.6.6.5 Insulation resistance

Where a cable is required to comply with this Clause, the minimum insulation resistance between any two conductors forming a pair, a quad or a coaxial tube—

- (a) **shall not** be less than the relevant value given in Table 5;
- (b) the measurement **shall** be made on a minimum length of 100 m of cable or cordage at a potential of 500 V d.c.  $\pm$ 50 V d.c. and the reading taken after the application of the voltage for 60 s; and
- (c) the insulation resistance **shall** be corrected to a length of 1000 m by application of the following equation:

$$\text{Value corrected to 1000 m length} = \text{measured value} \times \frac{L}{1000}$$

where:  $L$  is the length in metres of the cable under test

**Table 5**  
**Metallic cable performance parameters**

Cable parameter	Units	Cordage	Indoor cable and jumper wire	Outdoor cable— aerial	Outdoor cable— underground
Maximum mutual capacitance in telephone cable	nF/km	—	Unshielded twisted pair 80	52	49
			Shielded or parallel 120	52	49
Maximum capacitance unbalance pair to pair in telephone cable	pF (corrected to 500 m length)	—	2 pair/star quad cable 1000	2 pair/star quad cable 500	2 pair/star quad cable 500
			> 2 pair cable 300	> 2 pair cable 150	> 2 pair cable 150
Minimum insulation resistance for all metallic cables	M $\Omega$ .km	100	1,000	10,000	10,000

### 5.6.7 Metallic shield

Where a cable is required to comply with this Clause—

- (a) any shield provided in the cable **shall** be electrically continuous; and
- (b) where a foil shield is employed, a drain wire **shall** be placed in continuous contact with the metallic surface of the shield to ensure electrical continuity.

Note: Annex J of AS/NZS 60950.1 [20] gives recommendations for avoiding certain combinations of metals that could lead to corrosion.

### 5.6.8 Water penetration test

A cable that is required to comply with this Clause **shall** comply with the requirements for Water Penetration specified in Clause 25, Method –F5B of IEC 60794-1-2 [28].

Note 1: Water penetration refers to the effectiveness of a cable in restricting the longitudinal movement of water or moisture along the core. This requirement is primarily intended to localise any water penetration to minimise the adverse effect on cable performance and to prevent water or moisture leaking into joints and terminations that may cause corrosion problems.

Note 2: Additionally, cable installed underground should have a high-density compound sheath material (such as polyethylene) that provides an adequate barrier to moisture entry to the cable core. The addition of a lapped metal tape ('moisture barrier') and/or grease or gel within the core ('filled' or 'flooded' cable) provides even higher protection against moisture entry.

Note 3: Cable susceptible to ant/termite attack or that is buried directly in the ground without conduit should be of a type that provides additional mechanical protection against abrasion and insects such as a nylon jacket with an optional sacrificial jacket.

Note 4: Not all cables marketed as 'outdoor' or 'indoor/outdoor' cables meet the water penetration requirements for underground use. Manufacturers should clearly identify products intended to be installed underground.

*Compliance testing for water penetration using method –F5B can be conducted without the bending pre-conditioning of the cable under test.*

### 5.6.9 Integral bearer or strengthener

A cable that is intended for aerial use may contain an integral bearer or strengthener. Where an integral bearer/strengthener is provided:

- (a) The cable sheath **shall** fit closely over, but not adhere to, the bearer/strengthener.

Note: The sheath over the integral bearer/strengthener may be of cottage-loaf (i.e. figure-of-eight) construction.

- (b) The strength of the bearer/strengthener **shall** be sufficient to carry the load of the cable under the specified conditions.
- (c) The specified conditions referred to in Item (b) **shall** be stated in a product data sheet.
- (d) The product data sheet **shall** state the maximum allowable span, tension, sag, wind speed, ambient temperature range, and other parameters applicable to its use.

Note: Some of the data should be provided in the form of a table specifying, for example, allowable tension/sag values at various span lengths and temperatures.

#### 5.6.10 Cable with specific attributes

Where a cable is claimed to have specific attributes, such as rodent or termite resistance or armouring strength, evidentiary documentation **shall** be made available on request to support the claim.

*Compliance is assessed by the manufacturer's declaration stating the basis of the declaration, which may include known properties of the materials used.*

#### 5.6.11 Metallic paired cable

##### 5.6.11.1 General requirements

Metallic paired cable, other than cordage, a cord or a special application cable, **shall** comply with the following Clauses:

- 5.6.2 Conductor and optical fibre identification
- 5.6.3 Insulation and sheath material
- 5.6.4 Flammability (if intended for use within a building)
- 5.6.5 UV resistance (if intended for use external to a building, including underground)
- 5.6.6.1 Conductor composition
- 5.6.6.2 Electrical withstand voltage
- 5.6.6.3 Mutual capacitance (if intended for use as a telephone cable)
- 5.6.6.4 Capacitance unbalance (if intended for use as a telephone cable)
- 5.6.6.5 Insulation resistance
- 5.6.7 Metallic shield (if applicable)
- 5.6.8 Water penetration test (if intended for use underground)
- 5.6.9 Integral bearer or strengthener (if intended for aerial use without a separate catenary support)

5.6.11.2 Construction

A cable intended to carry a frequency of 300 Hz or greater **shall** be shielded or of twisted pair construction.

5.6.12 Cordage with metallic conductors

5.6.12.1 General requirements

Cordage with metallic conductors **shall** comply with the following Clauses:

- 5.6.2 Conductor and optical fibre identification
- 5.6.3 Insulation and sheath material
- 5.6.4 Flammability
- 5.6.5 UV resistance (if intended for use external to a building)
- 5.6.6.1 Conductor composition
- 5.6.6.2 Electrical withstand voltage
- 5.6.6.3 Mutual capacitance (if intended for use as telephone cordage)
- 5.6.6.4 Capacitance unbalance (if intended for use as telephone cordage)
- 5.6.6.5 Insulation resistance
- 5.6.7 Metallic shield (if applicable)

5.6.12.2 Conductor composition

Conductors in metallic cordage should be of stranded or tinsel conductor construction when frequent movement of the cordage is anticipated.

5.6.13 Cords with metallic conductors

5.6.13.1 General requirements

A cord with metallic conductors **shall** comply with the following Clauses:

- 5.6.2 Conductor and optical fibre identification
- 5.6.4 Flammability
- 5.6.5 UV resistance (if intended for use external to a building)
- 5.6.6.1 Conductor composition
- 5.6.6.2 Electrical withstand voltage
- 5.6.6.5 Insulation resistance
- 5.6.7 Metallic shield (if applicable)

5.6.13.2 Cords exceeding a length of 10 m

A cord with metallic conductors that exceeds a length of 10 m **shall** comply with Clause 5.6.13.1 and the following Clauses:

- 5.6.3 Insulation and sheath material

- 5.6.6.3 Mutual capacitance (if intended for use as a telephone cord)
- 5.6.6.4 Capacitance unbalance (if intended for use as a telephone cord)

### 5.6.13.3 Cord anchorage or strain relief

A cord with metallic conductors—

- (a) **shall** be secured in any plug or socket connected to a cord by an appropriate anchorage or strain relief; and
- (b) when subjected to a force of 45 N gradually applied between the cord and the plug or socket for a period of 60 s, the cord **shall not** be longitudinally displaced by more than 2 mm, nor show any appreciable strain at the connection.

Note: For measurement of longitudinal displacement, a mark is made on the cord approximately 20 mm from the cord anchorage or other suitable point before the test. The displacement of the mark is measured 60 s after the removal of the force from the cord.

### 5.6.14 Metallic jumper wire and jumper cable

#### 5.6.14.1 General requirements

Metallic jumper wire and jumper cable **shall** comply with the following Clauses:

- 5.6.2 Conductor and optical fibre identification
- 5.6.3 Insulation and sheath material
- 5.6.4 Flammability
- 5.6.6.1 Conductor composition
- 5.6.6.2 Electrical withstand voltage
- 5.6.6.5 Insulation resistance
- 5.6.7 Metallic shield (if applicable)

#### 5.6.14.2 Twist rate

Metallic jumper wire and cable **shall** have a minimum of 13 twists/metre in each pair.

### 5.6.15 Coaxial cable

#### 5.6.15.1 General requirements

Coaxial cable **shall** comply with the following Clauses:

- 5.6.2 Conductor and optical fibre identification (if applicable, i.e. contains more than one coaxial tube)
- 5.6.3 Insulation and sheath material
- 5.6.4 Flammability (if intended for use within a building)
- 5.6.5 UV resistance (if intended for use external to a building, including underground)

- 5.6.6.1 Conductor composition
- 5.6.6.2 Electrical withstand voltage
- 5.6.6.5 Insulation resistance
- 5.6.7 Metallic shield
- 5.6.9 Integral bearer or strengthener (if intended for aerial use without a separate catenary support)

Note: Coaxial cable intended for underground use is not required to meet the water penetration test of Clause 5.6.8 but should be of the 'flooded' type.

#### 5.6.15.2 Velocity ratio

The velocity ratio, determined according to Clause 13 of IEC 60096-1 [22], **shall** be a minimum of 0.65.

#### 5.6.15.3 Characteristic impedance

The characteristic impedance, measured according to Clause 14 of IEC 60096-1 [22], **shall** be  $Z_0 \pm Z_0/25$ , where  $Z_0$  is the nominal characteristic impedance specified by the manufacturer.

#### 5.6.15.4 Attenuation

The attenuation should be less than or equal to that specified by the manufacturer at 200 MHz when measured in accordance with Clause 16 of IEC 60096-1 [22].

#### 5.6.16 Optical fibre cable

##### 5.6.16.1 General requirements

Optical fibre cable, other than a blown fibre tube system, **shall** comply with the following Clauses:

- 5.6.2 Conductor and optical fibre identification
- 5.6.3 Insulation and sheath material (sheath requirement only)
- 5.6.4 Flammability (if intended for use within a building)
- 5.6.5 UV resistance (if intended for use external to a building, including underground)
- 5.6.8 Water penetration test (if intended for use underground)
- 5.6.9 Integral bearer or strengthener (if intended for aerial use without a separate catenary support)

##### 5.6.16.2 Fibre requirements

Multimode and single-mode fibres **shall** meet the relevant requirements of IEC 60793-2 [26].

##### 5.6.16.3 Mechanical and environmental performance

The supplier **shall** make available to the customer, on request, a Product Data Sheet as per the appropriate procedures in

IEC 60794-1-1 [27], specifying the mechanical and the environmental performance of a particular cable design.

#### 5.6.16.4 Optical fibre cords

Optical fibre cordage **shall** be secured in any plug or socket by an appropriate anchorage or strain relief so that when subjected to a force of 45 N gradually applied between the cordage and the plug or socket for a period of 60 s, the cordage **shall not** be longitudinally displaced by more than 2 mm, nor show any appreciable strain at the connection.

Note: For measurement of longitudinal displacement, a mark is made on the cordage approximately 20 mm from the cordage anchorage or other suitable point before the test and the displacement of the mark is measured while the cord is subjected to the pull.

#### 5.6.17 Blown fibre tube systems

##### 5.6.17.1 General requirements

A blown fibre tube system **shall** comply with the following Clauses:

- 5.6.2 Conductor and optical fibre identification
- 5.6.3 Insulation and sheath material
- 5.6.4 Flammability (if intended for use within a building)
- 5.6.5 UV resistance (if intended for use external to a building, including underground)
- 5.6.9 Integral bearer or strengthener (if intended for aerial use without a separate catenary support)

Note: A blown fibre tube system has characteristics that are distinct from those of conventional cable and is therefore exempt from the water penetration test of Clause 5.6.8 when used underground.

##### 5.6.17.2 Outer tube or sheath

The outer tube or sheath of an underground blown fibre tube system **shall** comply with the requirements of IPX8 of AS 60529 [18].

#### 5.6.18 Special application cables

##### 5.6.18.1 Compliance

A cable intended for a special application and intended for use in a cabling system connected to a carrier's network is required to comply with this Standard.

##### 5.6.18.2 General requirements

A special application cable installed within a building **shall** comply with Clause 5.6.4.

### 5.6.18.3 Cable with metallic conductors

A special application cable with metallic conductors—

(a) **shall** comply with the testing requirements of the relevant Standard, in order of priority, from Australian/New Zealand Standard or ISO/IEC Standard or other national published Standard applicable to that particular type of cable, as listed by way of example in Table 6, to meet the requirements for its intended use; or

(b) where Clause 5.6.18.3(a) is not applicable—

(i) the cable should comply with the following Clauses of this Standard:

5.6.6.1 Conductor composition;

5.6.6.2 Electrical withstand voltage;

5.6.6.5 Insulation resistance;

5.6.7 Metallic shield (if applicable); and

(ii) where the cable is intended to be used as a telephone cable, it **shall** comply with the following Clauses of this Standard:

5.6.6.3 Mutual capacitance;

5.6.6.4 Capacitance unbalance.



**Table 6**

**Australian Standards applicable for cables used in special applications**

<b>Cable type</b>	<b>Standard to be tested to</b>	<b>Name of Standard</b>	<b>Additional notes</b>
<b>Multicore control cables</b> (Screened and unscreened polymeric insulated multicore control cables)	AS/NZS 5000.3 [17]	Electrical cables – polymeric insulated. Multicore control cables	Intended for use in control, supervisory, protection and instrumentation circuits. This Standard does not apply to cables that are used solely for telecommunications purposes.
<b>Twisted pair control cables</b> (Screened polyethylene (PE) insulated twisted pair control cables)	AS/NZS 2373 [9]	Twisted Pair Control Cables	Intended for use in control, supervisory, protection and instrumentation circuits. This Standard does not apply to cables that are used solely for telecommunications purposes.
<b>Fire resistant or retardant rated cable</b> (with polymeric materials)	AS/NZS 5000.1 [15]	Electric cables-Polymeric insulated. For working voltages up to and including 0.6/1 kV	This Standard does not apply to specialised polymeric insulated cables for which there are separate AS/NZS Standards, e.g. flexible lift control cables, neutral screened cables, and aerial bundled cables.
	AS/NZS 5000.2 [16]	Electric cables-Polymeric insulated. For working voltages up to and including 450/750 V	
<b>Pyro MIMS (mineral-insulated metal sheathed) cables</b> (with copper conductors and sheaths)	AS/NZS 3188 [11]	Approval and test specification- Terminations and glands for mineral-insulated metal-sheathed cables	Often used in telecommunications installations to connect the fire alarm panel to the carrier's network.
<b>Reeling and trailing cables</b>	AS/NZS 1802 [6]	Electric cables-Reeling and trailing- For underground coal mining purposes	For underground mining purposes.
<b>Flexible cord,</b> unscreened PVC insulated, multicore, sheathed or unsheathed	AS/NZS 3191 [12]	Flexible Cords	Often used in Fire Alarm situations between fire alarm panel and warning devices.
<b>Other applications</b>			
• Hybrid cables	The relevant Standard for the non-telecommunications component of the cable		The equivalent of double insulation is to be provided between any power component and the telecommunications component of the cable
• Other cables	Clause 5.6.18.3 of this Standard		

## 5.7 Connecting hardware, including plugs and sockets of all designs

### 5.7.1 General

#### 5.7.1.1 Insulation resistance

The insulation resistance between any two points which are required to be electrically insulated **shall** be a minimum of 100 M $\Omega$ . The insulation resistance measurement is to be made after 500 V  $\pm$  50 V d.c. has been applied for a period of 60 s.

*Compliance with Clause 5.7.1.1 should be checked using the method specified in Test 3a of AS 3726.2 [13].*

#### 5.7.1.2 Contact resistance

##### 5.7.1.2.1 Insulation Displacement contacts

The contact resistance of the interface between a single insulated solid or stranded conductor and a single Insulation Displacement (ID) contact in connecting hardware other than the types of plugs and sockets covered in Clauses 5.7.2, 5.7.3 and 5.7.4 **shall** comply with the requirements of IEC 60352-4 [24] Clause 12.3.1, including Table 2 of that Clause.

##### 5.7.1.2.2 Plug and socket connection

For connectors using a plug and socket, including the connection of shield or drain-wire conductors, other than the types of plugs and sockets described in Clauses 5.7.2, 5.7.3 and 5.7.4, the interface resistance of the overall mated connection or shield connection **shall not** exceed 50 m $\Omega$  when measured between the cord terminated on the plug and the cable terminated on the socket using the test method described in Clause 12.3.1 of IEC 60352-4 [24].

Note: Appendix J of AS/NZS 60950.1 [20] gives recommendations for avoiding certain combinations of different metals, the combination of which could lead to corrosion.

#### 5.7.1.3 Electric strength

Electrically conductive elements normally at telecommunications network voltage (TNV) **shall** comply with Clause 6.2.2 (Voltage proof) of IEC 60603-7 [25].

#### 5.7.1.4 Protection against contact with exposed circuits

Connectors, plugs and sockets with metallic conductors and shields **shall** comply with the probe test of Clause 6.2.1 (b) (Separation requirements) of AS/NZS 60950.1 [20].

#### 5.7.1.5 Weather resistance

Plugs and sockets intended for use in situations exposed to weather and damp areas **shall** have a minimum degree of protection of IPX3

against the ingress of water when tested in accordance with AS 60529 [18].

*Compliance with Clause 5.7.1.5 should be checked with a plug both inserted into and removed from the socket.*

#### 5.7.2 Eight (8) position modular plugs and sockets

In addition to the general requirements of Clause 5.7.1, eight (8) position modular plugs and sockets **shall** comply with the following Clauses of IEC 60603-7 [25]:

- 6.2.3 Current carrying capacity
- 6.2.4 Initial contact resistance
- 6.3.1 Mechanical operation (Cycle)
- 6.3.2 Effectiveness of a connector coupling device

#### 5.7.3 Six (6) position modular plugs and sockets

Six (6) position modular plugs and sockets **shall—**

- (a) be mechanically designed according to CFR FCC 47.500(a) and (b) [29]; and
- (b) in addition to the general requirements of Clause 5.7.1, **shall** comply with the following Clauses of IEC 60603-7 [25]:
  - 6.2.3 Current carrying capacity
  - 6.2.4 Initial contact resistance
  - 6.3.1 Mechanical operation (Cycle)
  - 6.3.2 Effectiveness of a connector coupling device

#### 5.7.4 600 series plugs and sockets

600 series sockets are not supported for new installations.

600 series plugs and sockets manufactured to support existing installations **shall** comply with Appendix A.

### 5.8 Cabling products for underground and aerial installations

#### 5.8.1 Pits

The following requirements apply to pits:

- (a) The mechanical integrity of pits **shall not** be adversely affected by long-term exposure to moisture and sunlight (UV radiation).
- (b) When subjected to two single drop tests, one on the bottom and one on the side, from a height of 3 m onto a 3 mm thick steel plate, the pit **shall not** fracture.

- (c) When subjected to a vertically applied compressive load of 5 kN centrally applied by a 100 mm x 100 mm plate the pit **shall** maintain its structural integrity.
- (d) When subjected to a horizontally applied compressive force of 5 kN applied over the area of the larger side, the pit will maintain its structural integrity and **shall not** suffer from distortion of the rim.
- (e) Entry holes for conduits should be capable of being sealed to prevent siltation of the pit.
- (f) The pit cover **shall** be legibly and permanently labelled with the word 'Communications' or 'Comms', to distinguish it from pits of other services.

*Compliance with Clause 5.8.1(a) should be checked on the basis of known properties of the materials used.*

*Compliance with Clauses 5.8.1(c) and (d) should be checked with the pit lid in place, any joint supports included and cable entry knockouts removed.*

#### 5.8.2 Underground joint/termination enclosures

The following requirements apply to underground joint/termination enclosures:

- (a) Underground enclosures **shall** provide protection of the joint or termination of at least IPX8 in accordance with AS 60529 [18], with test conditions to simulate normal conditions of use.
- (b) The test **shall** be carried out with a depth of 500 mm of water for a duration of 24 hours.
- (c) Enclosures which are re-openable **shall** be opened and closed 10 times prior to the test.
- (d) Terminations may form part of the enclosure or they may be separate. In either case the terminations **shall** be protected to at least IPX8 in accordance with AS 60529 [18] when installed in the enclosure. See Clause 5.8.2(a) above.

Note: For testing purposes, cable may be required to be supplied by the manufacturer.

#### 5.8.3 Underground and aerial cable terminations

Underground and aerial terminations **shall** comply with Clauses 5.7.1.1 to 5.7.1.4.

#### 5.8.4 Pillars and cabinets

The following requirements apply to pillars and cabinets:

- (a) The mechanical integrity of pillars and cabinets **shall not** be adversely affected by long-term exposure to moisture and sunlight (UV radiation).

*Compliance with Clause 5.8.4(a) should be checked on the basis of known properties of the materials used.*

- (b) Pillars and cabinets **shall** provide protection of at least IPX3 in accordance with AS 60529 [18] after opening and closing 10 times prior to the test.
- (c) Provision **shall** be made for locking pillars and cabinets.
- (d) Terminations within pillars and cabinets **shall** comply with Clauses 5.7.1.1 to 5.7.1.4.
- (e) Pillars and cabinets should be legibly and permanently labelled to distinguish them from those used for other services.

#### 5.8.5 Aerial joint/termination enclosures

The following requirements apply to aerial joint/termination enclosures:

- (a) Aerial enclosures **shall** provide protection of the joint or termination of at least IPX3 in accordance with AS 60529 [18].
- (b) Enclosures that are re-openable **shall** be opened and closed 10 times prior to the test.
- (c) Covers of aerial enclosures should be removable to allow access to terminations when installed.
- (d) Aerial enclosures **shall** provide double insulation from internal terminations to 240 V a.c. grade in accordance with AS/NZS 60950.1 [20].
- (e) The mechanical integrity of aerial enclosures **shall not** be adversely affected by long-term exposure to weather and sunlight (UV radiation).

*Compliance with Clause 5.8.5(e) should be checked is assessed on the basis of known properties of the materials used.*

- (f) Terminations may form part of the aerial enclosure or may be separate. In either case the terminations **shall** be protected to at least IPX3 in accordance with AS 60529 [18] when installed in the enclosure.

Note: Terminations in aerial enclosures also need to comply with Clauses 5.7.1.1 to 5.7.1.4.

## **APPENDIX A (Normative)**

### **600 SERIES PLUGS AND SOCKETS**

#### **A.1 General**

600 series sockets are not supported for new installations. See Clause 5.7.4 of this Standard.

600 series plugs and sockets that are manufactured to support existing installations **shall** comply with this Appendix A.2 to A.5.

Note: Appendix C of AS/ACIF S009 [21] provides more information about 600 series sockets.

#### **A.2 Contact composition**

Contact metal **shall** be composed of solid Monel Alloy 400 in accordance with the standard composition of nickel copper alloy type NA 13.

#### **A.3 Mechanical compatibility**

Sockets should be designed to accept one or more of the 600 series plugs. The nominal mating dimensions of 600 series plugs and sockets **shall** be in accordance with Figure A1.


Note: Sockets may incorporate switching facilities that operate on the insertion and withdrawal of the plug.

#### **A.4 Connections**

Plugs and sockets **shall** have, as a minimum, electrical connections corresponding to contacts 2 and 6 in accordance with Figure A1.

#### **A.5 Resistance of plug/socket combination**

With the plug inserted into the socket, the maximum resistance between the cord terminated onto the plug and the cable terminated onto the socket **shall not** exceed 50 m $\Omega$  when tested with an applied voltage not exceeding 50 mV d.c. and an applied current not exceeding 100 mA.



Note 1: On both views, the cover has been removed for clarity.

Note 2: Dimensions are in mm.

**Figure A1**  
**Mating dimensions for 600 series plugs and sockets**

## APPENDIX B (Informative) CABLE COLOUR CODES

Common colour codes for various types of cable are described in AS/ACIF S009 [21] Tables B1 to B7. These tables are reproduced here to provide continuity between the Standards. Cable manufacturers usually follow these colour codes. Cables are required to use some method of coding that enables pairs and conductors to be visually distinguishable from one another (refer to Clause 5.6.2 of this Standard) but it is not mandatory for cable manufacturers to follow these colour codes.

**Table B1**

### 2-pair (quad) and 3-pair telephone cable colour code

Pair Number	Colours
1	White Blue
2	Red Black
3	Orange Green

**Table B2**

### 1-pair to 5-pair cable colour code

Pair number	Colour code variations		
1	White Blue	White-Blue Blue	White-Blue * Blue-White *
2	White Orange	White-Orange Orange	White-Orange * Orange-White *
3	White Green	White-Green Green	White-Green * Green-White *
4	White Brown	White-Brown Brown	White-Brown * Brown-White *
5	White Grey	White-Grey Grey	White-Grey * Grey-White *
* The first-named colour is the predominant colour			



**Table B3**  
**Colour code for 5-pair to 100-pair cables (20-pair units)**

Pair number	A Leg (L+)	B Leg (L-)	Pair range	Mate colour
1	White	Blue	1-20	White
2	White	Orange		
3	White	Green		
4	White	Brown		
5	White	Grey		
6	White	Blue-White	21-40	Yellow
7	White	Blue-Orange		
8	White	Blue-Green		
9	White	Blue-Brown		
10	White	Blue-Grey		
11	White	Orange-White	41-60	Black
12	White	Orange-Green		
13	White	Orange-Brown		
14	White	Orange-Grey		
15	White	Green-White		
16	White	Green-Brown	61-80	Violet
17	White	Green-Grey		
18	White	Brown-White		
19	White	Brown-Grey		
20	White	Grey-White		
			81-100	Red

Note: These cables are normally constructed using layer stranding, with the pair count sequence commencing from the centre and progressing through successive outer layers.

**Table B4**

**Colour code for 25-pair to 100-pair cables (25-pair units)**

Pair number	Mate	Colour	Pair range	Whipping colour
1	White	Blue	1-25	Blue
2	White	Orange		
3	White	Green		
4	White	Brown		
5	White	Grey		
6	Red	Blue	26-50	Orange
7	Red	Orange		
8	Red	Green		
9	Red	Brown		
10	Red	Grey		
11	Black	Blue	51-75	Green
12	Black	Orange		
13	Black	Green		
14	Black	Brown		
15	Black	Grey		
16	Yellow	Blue	76-100	Brown
17	Yellow	Orange		
18	Yellow	Green		
19	Yellow	Brown		
20	Yellow	Grey		
21	Violet	Blue		
22	Violet	Orange		
23	Violet	Green		
24	Violet	Brown		
25	Violet	Grey		

Note 1: 50 to 100 pair cables are constructed with 25 pair sub-units and coloured whipping.

Note 2: The mate conductor may include a thin band of the corresponding colour, while the coloured conductor may have a thin band of the corresponding mate colour.

**Table B5**

**Colour code for 5-pair to 100-pair cables (10-pair units)**

Pair number	A Leg (L+)	B Leg (L-)
1	White	Blue
2	White	Orange
3	White	Green
4	White	Brown
5	White	Grey
6	Red	Blue
7	Red	Orange
8	Red	Green
9	Red	Brown
10	Red	Grey

Pair range	Whipping colour
1-10	Blue
11-20	Orange
21-30	Green
31-40	Brown
41-50	Grey
51-60	Blue-White
61-70	Orange-White
71-80	Green-White
81-90	Brown-White
91-100	Grey-White

**Table B6**

**Colour code for 5-pair to 200-pair cables (10-pair units)**

Pair number	A Leg (L+)	B Leg (L-)
1	White	Blue
2	White	Orange
3	White	Green
4	White	Brown
5	White	Grey
6	Red	Blue
7	Red	Orange
8	Red	Green
9	Red	Brown
10	Red	Grey

Pair range	Whipping colour
1-10	Blue-White
11-20	Orange-White
21-30	Green-White
31-40	Brown-White
41-50	Grey-White
51-60	Blue-Blue
61-70	Orange-Orange
71-80	Green-Green
81-90	Brown-Brown
91-100	Grey-Grey
101-110	White-White
111-120	Red-Red
121-130	Yellow-Yellow
131-140	Violet-Violet
141-150	Black-Black
151-160	Blue-Red
161-170	Orange-Red
171-180	Green-Red
181-190	Brown-Red
191-200	Grey-Red

**Table B7**  
**Optical fibre colour code**

<b>Fibre number</b>	<b>Colour</b>
1	Blue
2	Orange
3	Green
4	Brown
5	Grey
6	White
7	Red
8	Black
9	Yellow
10	Violet
11	Pink
12	Aqua

Note 1: This colour code applies to both loose tube and tight buffered fibre.

Note 2: For stranded (multiple) loose tube constructions, the tube colour sequence is the same as the fibre colour sequence.

## 6 PARTICIPANTS

The ACIF Working Committee that developed this Standard consisted of the following organisations:

<b>Organisation</b>	<b>Membership</b>	<b>Name</b>
ADC Krone	Voting	Peter Meijer
AEEMA (Prysmian Telecom Cables)	Voting	Andrew Kaczmariski
ASIAL (Chubb Electronic Security)	Voting	Clifford Vituli
Australian Communications and Media Authority	Non-voting	Rob Pruyers
Belden Australia	Voting	George Karanikolaou
Belden Australia	Non-voting	Jim Boukouvalas
BICSI (Anixter Australia)	Voting	Barney Tomasich
Clipsal Datacomms	Voting	Colin Browitt
Electrical & Communications Association (ECA)	Voting	Lex Batterham
FPAA (Bassett Consulting Engineers)	Voting	Frank Mendham
FPAA (Interactive Fire)	Non-voting	Troy Haynes
General Cable Australia	Voting	Zoltan Jakab
International Testing and Certification Services	Voting	Jurek Botiuk
Macable	Voting	Neil MacDonald
NECA (Panduit International)	Voting	Ian Gale
Optus	Voting	Eric Christoph
Optus	Non-voting	Joseph Lovric
Ramsden Telecommunications Training	Voting	Bevan Ramsden
Siemon	Voting	Brad Duce
Standards Australia (Jamsam)	Voting	John Ward
Telstra	Voting	Terry Phillips
VTI Services	Non-voting	Murray Teale

This Working Committee was chaired by Murray Teale. Peter Meijer provided editorial support. James Duck and Mike Johns ACIF provided project management support.

NOTES

The policy objective of the greatest practicable use of industry self-regulation without imposing undue financial and administrative burdens on industry is central to the regulatory scheme of the *Telecommunications Act 1997*.

ACIF was established to implement the policy of industry self-regulation. It is a company limited by guarantee and is a not-for-profit membership-based organisation. Its membership comprises carriers/carriage service providers, business and residential consumer groups, industry associations and individual companies.

ACIF's mission is to develop collaborative industry outcomes that foster the effective and safe operation of competitive networks, the provision of innovative services and the protection of consumer interests. In the development of Industry Codes and Technical Standards as part of its mission, ACIF's processes are based upon its principles of openness, transparency, consensus, representation and consultation. Procedures have been designed to ensure that all sectors of Australian society are reasonably able to influence the development of Standards and Codes. Representative participation in the work of developing a Code or Standard is encouraged from relevant and interested parties. All draft Codes and Standards are also released for public comment prior to publication to ensure outputs reflect the needs and concerns of all stakeholders.



Published by:  
**THE AUSTRALIAN  
COMMUNICATIONS  
INDUSTRY FORUM LTD**

Level 9  
32 Walker Street  
North Sydney  
NSW 2060 Australia

Correspondence:  
PO Box 444  
Milsons Point  
NSW 1565

T 61 2 9959 9111  
F 61 2 9954 6136  
TTY 61 2 9923 1911  
E [acif@acif.org.au](mailto:acif@acif.org.au)  
[www.acif.org.au](http://www.acif.org.au)  
ABN 56 078 026 507

Care should be taken to ensure that material used is from the current version of the Standard or Industry Code and that it is updated whenever the Standard or Code is amended or revised. The number and date of the Standard or Code should therefore be clearly identified. If in doubt please contact ACIF.

ISBN: 1 74000 351 9